

CERTIFICATE OF CALIBRATION

Unit Model #:

195374

Unit Serial #:

MD320095G

Recorder Serial #: PL1411000559-1014-PL3

Instrument #:

8462050

MAC Address:

00:0A:8D:81:1E:E2

Sure Controls does hereby certify the above instrument was calibrated against standards maintained by Sure Controls and meets or exceeds all published specifications. The accuracy of these standards is directly traceable to the National Institute of Standards and Technology.

		Displayed Value	
Recorder	Primary Standard Signal 382.0 ° F	Primary Standard Signal 882.0° F	Primary Standard Signal 1382.0° F
CHANNEL 1	382	882	1382
CHANNEL 2	382	882	1382
CHANNEL 3	382	882	1382
CHANNEL 4	382	882	1382
CHANNEL 5	382	882	1382
CHANNEL 6	382	882	1382
Calibration Date:	4/30/2014		
Recalibration Date:	4/30/2015		

Certified by:

Instrumentation Used:

Beamex Model No. MC2 Multi-Function Calibrator

Beamex Serial No. 13533

Sure Controls ID No. STD-39